

イ 簡易水道

市町村名	水道事業名	経営区分	創設時 給水開始 年月	最新認可 年月日	人口			原水 種別	浄水施設		配水池		計画 1日最大 取水量 (m <sup>3</sup> /日)	1日最大給水量 (m <sup>3</sup> /日)		実績 1日平均 給水量 (m <sup>3</sup> /日)
					計画 給水	現在			処理能 力 (m <sup>3</sup> /日)	浄水方法	池 数	容 量		計画値	実績値	
						給水 区域内	給水									
那須町	平和郷	私	S45.10	H5.12.28	1,400	920	920	浅	350	消毒のみ	1	100	720	350	350	165
那須町	平和台	私	S46.10	H5.12.28	400	485	485	浅	230	消毒のみ	1	100	230			28
	那珂川水系				1,800	1,405	1,405		580		2	200	950	350	350	193
日光市	日光二社一寺	私	T15.6	T14.7.23	700	400	155	伏・自	3,800	緩速ろ過	2	360	4,000	3,800	1,879	1,753
	鬼怒川水系				700	400	155		3,800		2	360	4,000	3,800	1,879	1,753
鹿沼市	ヒルタウンさつき野	組	H4.2	H14.11.7	3,073	2,032	2,032	深	1,500	消毒のみ	2	854	1,480	1,100	735	591
	渡良瀬川水系				3,073	2,032	2,032		1,500		2	854	1,480	1,100	735	591
	合 計				5,573	3,837	3,592		5,880		6	1,414	6,430	5,250	2,964	2,538

水道事業名	水源の種類別・実績年間取水量(m <sup>3</sup> /年)								実績年間水量(m <sup>3</sup> /年)							
	ダム	湖水	自流	伏流水	浅井戸	深井戸	浄水 受水	その他	取水量	給水量	有収水量			無収 水量	有効 水量	無効 水量
											合計	生活用	その他			
平和郷					262,800				262,800	60,225	12,936	12,936		47,289	60,225	
平和台					76,650				76,650	10,398	10,398	10,398			10,398	
那珂川水系					339,450				339,450	70,623	23,334	23,334		47,289	70,623	
日光二社一寺			400,000	600,000					1,000,000	640,000	119,000	89,000	30,000	400,000	519,000	121,000
鬼怒川水系			400,000	600,000					1,000,000	640,000	119,000	89,000	30,000	400,000	519,000	121,000
ヒルタウンさつき野						223,800			223,800	215,800	213,550	196,650	16,900	1,150	214,700	1,100
渡良瀬川水系						223,800			223,800	215,800	213,550	196,650	16,900	1,150	214,700	1,100
合 計			400,000	600,000	339,450	223,800			1,563,250	926,423	355,884	308,984	46,900	448,439	804,323	122,100

市町村名	事業名	管種	管種別延長(m)／管種別構成比(%)									管路総計	耐震管	法定耐用年数超
			鋳鉄管	タワイル鋳鉄管	鋼管	石綿セメント管	硬質塩化ビニル管	コンクリート管	鉛管	ポリエチレン管	その他			
那須町	平和郷	導水管										0		
		送水管				530	1,182					1,712		
		配水管					15,150					15,150		
		合計	0	0	0	530	16,332	0	0	0	0	16,862	未把握	未把握
		構成比	0.0%	0.0%	0.0%	3.1%	96.9%	0.0%	0.0%	0.0%	0.0%	100.0%		
那須町	平和台	導水管					10					10		
		送水管					88					88		
		配水管					6,871					6,871		
		合計	0	0	0	0	6,969	0	0	0	0	6,969	未把握	未把握
		構成比	0.0%	0.0%	0.0%	0.0%	100.0%	0.0%	0.0%	0.0%	0.0%	100.0%		
那珂川水系	導水管	0	0	0	0	10	0	0	0	0	10			
	送水管	0	0	0	530	1,270	0	0	0	0	1,800			
	配水管	0	0	0	0	22,021	0	0	0	0	22,021			
	合計	0	0	0	530	23,301	0	0	0	0	23,831	0	0	
	構成比	0.0%	0.0%	0.0%	2.2%	97.8%	0.0%	0.0%	0.0%	0.0%	100.0%	0.0%	0.0%	
日光市	日光二社一寺	導水管	400				1,900					2,300		
		送水管	100									100		
		配水管	4,750	950			150			1,550		7,400		
		合計	5,250	950	0	0	2,050	0	0	1,550	0	9,800	2,100	未把握
		構成比	53.6%	9.7%	0.0%	0.0%	20.9%	0.0%	0.0%	15.8%	0.0%	100.0%	21.4%	
鬼怒川水系	導水管	400	0	0	0	1,900	0	0	0	0	2,300			
	送水管	100	0	0	0	0	0	0	0	0	100			
	配水管	4,750	950	0	0	150	0	0	1,550	0	7,400			
	合計	5,250	950	0	0	2,050	0	0	1,550	0	9,800	2,100	0	
	構成比	53.6%	9.7%	0.0%	0.0%	20.9%	0.0%	0.0%	15.8%	0.0%	100.0%	21.4%	0.0%	
鹿沼市	ヒルタウンさつき野	導水管					783					783		
		送水管										0		
		配水管		907			8,736					9,643		
		合計	0	907	0	0	9,519	0	0	0	0	10,426	未把握	未把握
		構成比	0.0%	8.7%	0.0%	0.0%	91.3%	0.0%	0.0%	0.0%	0.0%	100.0%		
渡良瀬川水系	導水管	0	0	0	0	783	0	0	0	0	783			
	送水管	0	0	0	0	0	0	0	0	0	0			
	配水管	0	907	0	0	8,736	0	0	0	0	9,643			
	合計	0	907	0	0	9,519	0	0	0	0	10,426	0	0	
	構成比	0.0%	8.7%	0.0%	0.0%	91.3%	0.0%	0.0%	0.0%	0.0%	100.0%	0.0%	0.0%	
簡易水道事業合計	導水管	400	0	0	0	2,693	0	0	0	0	3,093			
	送水管	100	0	0	530	1,270	0	0	0	0	1,900			
	配水管	4,750	1,857	0	0	30,907	0	0	1,550	0	39,064			
	合計	5,250	1,857	0	530	34,870	0	0	1,550	0	44,057	2,100	0	
	構成比	11.9%	4.2%	0.0%	1.2%	79.1%	0.0%	0.0%	3.5%	0.0%	100.0%	4.8%	0.0%	