

## Tochigi Prefecture Tap Water Test Results (June 10)

Tested on: Purified Tap Water

Unit: Bq/kg

Water System	Water Supplier	Latest Sample Date (M/D)	Radioactive Cesium	
			134	137
			Amount Detected	Amount Detected
Kinugawa River	Utsunomiya City	2022/5/19	Undetected ( < 0.40 )	Undetected ( < 0.70 )
	Nikko City	2022/3/9	Undetected ( < 0.60 )	Undetected ( < 0.60 )
	Moka City	<u>2022/6/7</u>	Undetected ( < 0.60 )	Undetected ( < 0.64 )
	Takanezawa Town	2022/1/10	Undetected ( < 0.81 )	Undetected ( < 0.81 )
	Kinu Waterworks *2	2022/5/12	Undetected ( < 0.75 )	Undetected ( < 0.76 )
Nakagawa River	Yaita City	2022/2/16	Undetected ( < 0.80 )	Undetected ( < 0.80 )
	Nasu-Shiobara City	2022/3/8	Undetected ( < 0.80 )	Undetected ( < 0.80 )
	Shioya Town	2022/5/20	Undetected ( < 0.80 )	Undetected ( < 0.80 )
	Nasu Town	2022/2/22	Undetected ( < 0.70 )	Undetected ( < 0.60 )
	Kita-Nasu Waterworks*3	2022/5/12	Undetected ( < 0.67 )	Undetected ( < 0.70 )
Omoigawa River	Oyama City	2022/3/15	Undetected ( < 0.75 )	Undetected ( < 0.89 )
	Nogi Town	2022/3/2	Undetected ( < 0.71 )	Undetected ( < 0.55 )
Ground-water	Ashikaga City	2022/4/19	Undetected ( < 0.80 )	Undetected ( < 0.47 )
	Tochigi City	2022/3/1	Undetected ( < 1.00 )	Undetected ( < 1.00 )
	Sano City	2022/3/4	Undetected ( < 1.00 )	Undetected ( < 0.90 )
	Kanuma City	2022/5/9	Undetected ( < 0.50 )	Undetected ( < 0.60 )
	Ohtawara City	2022/2/15	Undetected ( < 0.80 )	Undetected ( < 1.00 )
	Sakura City	2022/1/13	Undetected ( < 0.68 )	Undetected ( < 0.77 )
	Nasu-Karasuyama City	2022/6/1	Undetected ( < 0.60 )	Undetected ( < 0.75 )
	Shimotsuke City	2022/3/7	Undetected ( < 0.77 )	Undetected ( < 0.80 )
	Kaminokawa Town	2022/3/1	Undetected ( < 0.40 )	Undetected ( < 0.40 )
	Motegi Town	2022/5/24	Undetected ( < 0.72 )	Undetected ( < 0.70 )
	Mibu Town	2022/1/7	Undetected ( < 1.00 )	Undetected ( < 1.00 )
	Nakagawa Town	2022/3/8	Undetected ( < 0.80 )	Undetected ( < 0.80 )
	Haga Central Waterworks *1	<u>2022/6/6</u>	Undetected ( < 0.57 )	Undetected ( < 0.77 )
Management Target Value (Sum of Cesium 134 and 137)			10	

Underlined portions are reports released today.

\* Some cities and towns have multiple samples, but this table includes the highest values. For more information, please contact the city or town.

\*Lowest detectable limit is written in parentheses.

\*1 Homes in Mashiko Town, Ichikai Town and Haga Town are served by Haga Central Waterworks companies.

\*2 Kinu Waterworks (Business Administration) uses the Kinu Treatment Plant to supply water to a portion of Haga Central Waterworks companies and homes in Utsunomiya, Moka, and Takanezawa. Other homes receive water from the city/town.

\*3 Kita-Nasu Waterworks (Business Administration) uses the Kita-Nasu Treatment Plant to supply water to portions of Nasu-Shiobara and Otawara. The two cities supply water to homes in the area.

### Tap Water Testing at the Source (Separate River Waters)

Unit: Bq/kg

Water System	Sample Source	Latest Sample Date (M/D)	Radioactive Cesium	
			134	137
			Amount Detected	Amount Detected
Nakagawa River	Nasu-Shiobara City	<u>2022/4/14</u>	Undetected ( < 0.60 )	Undetected ( < 0.69 )
	Yaita City (Miyagawa River)	<u>2022/4/14</u>	Undetected ( < 0.61 )	Undetected ( < 0.69 )
Kinugawa River	Takanezawa Town	<u>2022/4/14</u>	Undetected ( < 0.64 )	Undetected ( < 0.79 )
Omoigawa River	Oyama City	<u>2022/4/14</u>	Undetected ( < 0.65 )	Undetected ( < 0.67 )

Underlined portions are reports released today.

\* Tap water source refers to untreated water.

\*Tap water source testing is conducted on sources that are collected at the water's surface. We have surveyed three river basins to represent the prefecture: Nakagawa, Kinugawa and Omoigawa Rivers.

\*Lowest detectable limit is written in parentheses.